

ATTESTATION OF CONFORMITY

Issued to: Staka Metallics
Innovatiepark 16
4906 AA Oosterhout
Netherlands

For the product: Empty Enclosure

Trade name: STAKA

Type/Model: RRN-Series, Model tested: RRNE1_D2_VENT

Ratings: IK10 / IP55

Manufactured by: Staka Metallics
Innovatiepark 16
4906 AA Oosterhout
Netherlands

Subject: Degree of protection provided by enclosure

Requirements: IEC 60529:1989 + A1:1999 + A2:2013
EN 60529:1991 + A1:2000 + A2:2013
IEC 62208:2023 (clause 9.8)

Remark: Fan inside the enclosure was not running during the IP5X test.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report 2280990.01 issued on 13 December 2023.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 18 December 2023

Number: 2280990.01-AOC

DEKRA Certification B.V.

H.L. Schendstok
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed